

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7125-1157:108 Page 1 of 1

CATEGORY: Fire Alarm Devices for the Hearing Impaired

LISTEE: Digital Monitoring Products, *2500 N. Partnership Blvd., Springfield, MO 65803
Contact: Terry Shelton (417) 831-9362 FAX (417) 831-1325

DESIGN: Models 803 horn; Models 823, 923-15W, -1575W, -30W, -75W, -110W and 923-MCW horn strobes. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING:

Electrical	10.5-31 VDC
Candela	15: 15cd, 30: 30cd, 1575: 15/75cd on axis, 75: 75cd, 110:110cd (wall)
Flash rate	60 Flashes/minute

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction. Horn strobes are for wall mount only.

MARKING: Listee's name, model number, electrical/candela rating and UL label.

APPROVAL: Listed as audible and audible/visual signaling devices for use with separately listed electrically compatible fire alarm control units. Models 823 and 923 are suitable for the hearing impaired. All units are intended for indoor use except for Model 803 is intended for use outdoor. For synchronization strobes, Models 831 or 832 Sync Control Module must be used (CSFM Listing No. 7300-1157:107).

NOTE: These appliances can produce a distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1999 Edition.

XLF: 7125-0785:142

*Rev. 03-04-2004



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 22, 2004**

*Listing Expires **June 30, 2005***

Authorized By: **DIANE K. AREND, Senior Deputy**
Program Manager